



OFFICE OF THE DISTRICT FIRE OFFICER,
KARNATAKA FIRE & EMERGENCY SERVICES,
ANJANPURA FIRE STATION, BENGALURU-560 108.



C.No: 20/DFO/AFS/BLR/FSCR-05/2024.

Dated: 06-02-2024

“Annexure-2”

To,
The Principal,
K Lakkappa Education Trust,
Shree Ram Public School,
V H Gardens, Chikkabidarakallu,
Nagasandra Post, Bengaluru-560 073.

Sir,

Sub: Issue of “Fire Safety Compliance report” with respect to fire prevention, fighting and evacuation measures maintained at **“M/s. K Lakkappa Education Trust, Shree Ram Public School, V H Gardens, Chikkabidarakallu, Nagasandra Post, Bengaluru – 560 073”**- reg.

Ref: 1) This office FSR C.No:20/DFO/AFS/BLR/FSR-05/2024; Date: 06-02-2023
2) Your request letter dated: 01-02-2024
3) Inspection report No.25/08/FSO/AFS/BLR/2024; D: - 02-02-2024.

<<<@ @ @ @ @>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of **M/s. K Lakkappa Education Trust, Shree Ram Public School, V H Gardens, Chikkabidarakallu, Nagasandra Post, Bengaluru – 560 073** with a condition to fulfill the recommendations issued.


With reference cited (2) above, the management of ‘M/s. Shree Ram Public School’, had requested for the of fire safety compliance report from our department. In this regard the above school building was inspected by me on 02-02-2024 and prepared the inspection report to reference cited (3) above, issue fire safety compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the **“Fire Safety Compliance Report”** of **“M/s. K Lakkappa Education Trust, Shree Ram Public School, V H Gardens, Chikkabidarakallu, Nagasandra Post, Bengaluru – 560 073”** subject to proper maintenance of firefighting installations in the good working conditions and arrange for 40% of staffs / employees training within 03 months from the date of issue of this report.

“This report is valid for only one year from the date of issue and is renewable without fail”.

Yours faithfully




DISTRICT FIRE OFFICER
Anjanapura Fire Station,
BANGALORE-560 108



OFFICE OF THE DISTRICT FIRE OFFICER,
KARNATAKA FIRE & EMERGENCY SERVICES,
ANJANPURA FIRE STATION, BENGALURU-560 108.



C.No:20/DFO/AFS/BLR/FSR-05/2024

dated: 06-02-2024

ANNEXURE-B
Group -B Educational Buildings

To,

The Principal,
K Lakkappa Education Trust,
Shree Ram Public School,
V M Gardens, Chikkabidarakallu,
Nagarsandra Post, Bengaluru-560073.

Sir,

Sub Issue of 'Fire safety recommendation' to "M/s. K Lakkappa Education Trust, Shree Ram Public School, V H Gardens, Chikkabidarakallu, Nagasandra Post, Bengaluru - 560 073"-- reg

Ref 1) Your Request latter dated: 01-02-2024
2) Inspection report No.25/08/FSO/AFS/BLR/2024; D - 02-02-2024

With reference to the subject cited above, the premises "M/s. K Lakkappa Education Trust, Shree Ram Public School, V H Gardens, Chikkabidarakallu, Nagasandra Post, Bengaluru - 560 073" was inspected by me on 02-02-2024 with respect to fire prevention, firefighting and evacuation measures to be complied in the above premises and has submitted the details as under:-

A. Details of the Building/premises.

1.	Name and address of the applicant	: The Principal, K Lakkappa Education Trust, Shree Ram Public School, V M Gardens, Chikkabidarakallu, Nagarsandra Post, Bengaluru-560073.
2.	Name and address of the premises.	: Shree Ram Public School, V M Gardens, Chikkabidarakallu, Nagarsandra Post, Bengaluru-560073.
3.	Name and address of the building owner	: K Lakkappa Education Trust, Shree Ram Public School, V M Gardens, Chikkabidarakallu, Nagarsandra Post, Bengaluru-560073
4.	Number of Buildings	: One Building with Two Block (Block-A and Block-B)
5.	Number of floors	: Block-A; Ground Floor and Four upper Floors. Block-B; Ground Floor and Four upper Floors.
6.	Floor wise details of occupancy	



	Block A	Ground floor	:	1 office room, 2 staff rooms, 1 principal room, 4 class rooms.
		First floor	:	6 class rooms, 2 labs.
		Second floor	:	6 class rooms, 2 wash rooms.
		Third floor	:	8 class rooms.
		Fourth floor	:	8 class rooms.
	Block B	Ground floor	:	2 staff rooms, 1 library, 5 class rooms.
		First floor	:	6 class rooms, 2 labs.
		Second floor	:	6 class rooms, 2 wash rooms.
		Third floor	:	6 class rooms, 2 wash rooms.
		Fourth floor	:	Auditorium
7.	Height of the Buildings.		:	14.50 mtrs.
8.	Site area		:	2308.00 Sq.mtrs.
9.	Built-up area of each floor:-			
	Block -A	Ground floor	:	449.70 sq.mtrs.
		First floor	:	449.70 sq.mtrs.
		Second floor	:	449.70 sq.mtrs.
		Third floor	:	449.70 sq.mtrs.
		Fourth floor	:	449.70 sq.mtrs.
	Block-B	Ground floor	:	449.70 sq.mtrs.
		First floor	:	449.70 sq.mtrs.
		Second floor	:	449.70 sq.mtrs.
		Third floor	:	449.70 sq.mtrs.
		Fourth floor	:	449.70 sq.mtrs.
10.	Total Built up area		:	4497.00 Sq.mtrs.
11.	Surroundings of the Property:-			
		North (front)	:	10.00 Mtrs. wide service road.
		South (rear)	:	Privet Property
		East (side)	:	Privet Property
		West (side)	:	Privet Property
12.	Setback area available around the building			
		North	:	Min 05.00 mtrs.
		South	:	Min 01.00 mtrs.
		East	:	Min 01.00 mtrs.
		West	:	Min 10.00 mtrs.

B. On inspection of the school building premises, the following fire prevention, fire Fighting and Evacuation measures are recommended considered absolutely essential from fire safety point of view:-

c.no (01)	Detail (02)	Existing (3)	Recommendations (4)
--------------	----------------	-----------------	------------------------



1.	Accessibility	The premises is accessible from 10.00 mtrs wide service road, located on the northern side. This road is hardened to carry the weight of 45,000 Kgs.	Adequate.
2.	Number of entrances	One entrance each of 06.00 width have been provided	Complied.
3.	Number of staircases available	Number of the staircases	02 Nos.
		Width of staircases	01.40 mtrs.
		Width of treads	30 cms.
		Height of risers	15 cms.
		No. of risers per flight	10/10 risers.
		Height of handrails	01.00 mtr.
		Head room clearance	2.60 mtrs.
4.	Portable extinguishers	<p>A. One water mist extinguisher of 9 ltrs capacity has be kept near each staircase landing.</p> <p>B. One mechanical foam extinguisher of 9 ltrs capacity & One ABC type extinguisher of 6 kgs capacity has be provided near diesel generator.</p> <p>C. One CO₂ type fire extinguisher, of 4.5 kgs capacity has be provided near each electrical panel board & electrical room.</p> <p>D. 05 No's ABC type fire extinguisher of 06 kgs capacity has be located each floor.</p>	Complied
5.	Hose reel hose system	02 No's of Hose Reel Hoses near the staircase (One hose reel hose system for every 1000 Sq. mtrs). The hose reel hose of min 19 mm size and of 30.00 mtrs length has be provided to reach the farthest point of each floor and shut off branch having a nozzle of 5mm size. The hose reel hose has been connected at each landing.	Complied
6.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	The hose reel hose & Automatic sprinkler systems has been connected to a booster pump capable of delivering 900 LPM. (Further the system has been connected to an alternative source of power supply.)	Complied



7.	Diesel generator	Diesel generator of 15 KVA Capacity has been provided to supply alternative power supply.	Complied
8.	Terrace tank	The system has been connected to an overhead tank of 20,000 ltrs capacity.	Complied
9.	Escape routes	Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.	Complied
10.	Fire order (Fire safety plans)	Notice boards, indicating with the details of action to be taken by the Staff/Students in case of an emergency/Fire has been displayed each floor with telephone numbers of Central Fire Control Room i.e. 22971500, 22971550 22971600 & 101 & 112 and of nearby Ambulance Service.	Complied
11.	No smoking board	COTPA Sec-4 direction No Smoking area smoking here is an offence board should be written in English & Kannada both language has been prominently displayed inside the entry / exit of the each floor.	Complied
12.	Fire Siren	A Fire Siren has been installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.	Complied
13.	Nominate one Fire Nodal Officer	--	A fire nodal officer shall be nominated either from teaching or non-teaching staff.
14.	Firefighting training	Not trained	At least 40% of Teaching and non-Teaching staff should be got trained in basic firefighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore or Regional Training centre



15.

Fire precautionary measures :-

- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should not be stored in the building.
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.

As per Hon'ble Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing '**Fire Safety Recommendation Certificate**' to "M/s. K Lakkappa Education Trust, Shree Ram Public School, V H Gardens, Chikkabidarakallu, Nagasandra Post, Bengaluru – 560 073" subject to condition and compliance of the above recommendations as shown in column-4 of Part-B within 3 months and compliance from the undersigned.

This Fire Safety Recommendation is valid for only one Year from the date of issue and it is renewable.

♣ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.



Yours faithfully,

DISTRICT FIRE OFFICER
Anjanapura Fire Station,
BANGALORE-560 108